

**AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.); the "CWA"), and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**Town of Bridgewater
Bridgewater Wastewater Treatment Facility**

is authorized to discharge from the facility located at

**Morris Avenue
Bridgewater, Massachusetts 02324**

to receiving water named

**Town River
Taunton River Watershed (62)**

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective sixty days from the date of signature.

This permit and the authorization to discharge expire at midnight, five (5) years from the effective date.

This permit supercedes the permit issued on September 30, 1998.

This permit consists of 11 pages in Part I including effluent limitations, monitoring requirements, Attachments A, B, and 35 pages in Part II including General Conditions and Definitions.

Signed this 30th day of December, 2003

/Signature on file/

Linda M. Murphy, Director
Office of Ecosystem Protection
Environmental Protection Agency
Boston, MA

Director
Division of Watershed Management
Bureau of Resource Protection
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

NPDES PERMIT NO. MA0100641

2003 Issuance, Page 2 of 11

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge treated sanitary wastewater from outfall serial number 001, into the Town River. Such discharge shall be limited and monitored by the permittee as specified below.

<u>Effluent Characteristic</u>	<u>Units</u>	<u>Discharge Limitation</u>			<u>Measurement Frequency</u>	<u>Monitoring Requirement</u>
		<u>Average Monthly</u>	<u>Average Weekly</u>	<u>Maximum Daily</u>		<u>Sample Type</u>
Flow	MGD	1.44	*****	Report	Continuous ²	Recorder
BOD ₅ ⁴	mg/l	20	30	Report	2/Week	24 Hour Composite ³
	lbs/day	240	360	Report	2/Week	24 Hour Composite ³
TSS ⁴	mg/l	20	30	Report	2/Week	24 Hour Composite ³
	lbs/day	240	360	Report	2/Week	24 Hour Composite ³
pH ¹	S.U.	(See Condition I.A.1.b. on Page 6)			1/Day	Grab ³
Dissolved Oxygen	mg/l	5.0 or greater			1/Day	Grab ³
Settleable Solids ⁵	ml/l	0.1 ml/l	0.1 ml/l	0.3 ml/l	1/Day	Grab ³
Fecal Coliform ^{1,6} (April 1 through October 31)	cfu's/100 ml	200	400	400	2/Week	Grab ³
Total Residual Chlorine ^{1, 6,7,8} (April 1 through October 31)	ug/l	24	*****	42	1/Day	Grab ³
Phosphorus, Total (April 1 through October 31)	mg/l	1.0	*****	*****	1/Week	24 Hour Composite ³
	lbs/day	12.0	*****	*****	1/Week	24 Hour Composite ³

NPDES PERMIT NO. MA0100641

2003 Issuance, Page 3 of 11

<u>Effluent Characteristic</u>	<u>Units</u>	<u>Discharge Limitation</u>			<u>Monitoring Requirement</u>	
		<u>Average Monthly</u>	<u>Average Weekly</u>	<u>Maximum Daily</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Phosphorus, Total (November 1 though March 31)	mg/l	Report	*****	*****	1/Month	24 Hour Composite ³
	lbs/day	Report	*****	*****	1/Month	24 Hour Composite ³
Copper, Total	ug/l	11	*****	15	1/Month	24 Hour Composite ³
Ammonia Nitrogen (April 1 through October 31)	mg/l	3.0	*****	*****	1/Week	24 Hour Composite ³
	lbs/day	36.0	*****	*****	1/Week	24 Hour Composite ³
Ammonia Nitrogen (November 1 through March 31)	mg/l	Report	*****	*****	1/Month	24 Hour Composite ³
	lbs/day	Report	*****	*****	1/Month	24 Hour Composite ³
Total Kjeldahl Nitrogen (TKN) (April 1 through October 31)	mg/l	Report	*****	Report	2/Month ⁹	24 Hour Composite ³
	lbs/day	Report	*****	Report	2/Month ⁹	24 Hour Composite ³
Total Kjeldahl Nitrogen (TKN) (November 1 through March 31)	mg/l	Report	*****	Report	1/Month	24 Hour Composite ³
	lbs/day	Report	*****	Report	1/Month	24 Hour Composite ³
NO ₂ /NO ₃ (Nitrite/Nitrate) (April 1 through October 31)	mg/l	Report	*****	Report	2/Month ⁹	24 Hour Composite ³
	lbs/day	Report	*****	Report	2/Month ⁹	24 Hour Composite ³
NO ₂ /NO ₃ (Nitrite/Nitrate) (November 1 through March 31)	mg/l	Report	*****	Report	1/Month	24 Hour Composite ³
	lbs/day	Report	*****	Report	1/Month	24 Hour Composite ³
NOEC ^{10,11,13}	%	*****	*****	45	4/Year	24 Hour Composite ³
LC ₅₀ ^{10,12,13}	%	*****	*****	100	4/Year	24 Hour Composite ³

Footnotes:

1. Required for State Certification.

2. For flow, report maximum and minimum daily rates and total flow for each operating date. This is an annual average limit, which shall be reported as a rolling average. The first value will be calculated using the monthly average flow for the first full month ending after the effective date of the permit and the eleven previous monthly average flows. Each subsequent month's DMR will report the annual average flow that is calculated from that month and the previous 11 months.

3. Effluent parameters that require 24-hour composite samples and grab samples shall be taken at the outfall structure after the chlorine contact chamber. Any change in sampling location must be reviewed and approved in writing by EPA and MADEP. All samples shall be tested using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.

A 24-hour composite sample will consist of at least twenty four (24) grab samples, which are flow proportional, and taken during one working day. Working day is defined as 8:00 am through 8:00 am the following day, eg 8:00 am Monday through 8:00 am Tuesday.

4. Sampling required for influent and effluent.
5. An additional grab sample for settleable solids shall be taken during times of peak flow. The sample shall be representative of the effluent being discharged to the river during peak flows.
6. Fecal coliform and total residual chlorine monitoring will be conducted seasonally. This is a State certification requirement. Fecal coliform discharges shall not exceed a monthly geometric mean of 200 colony forming units (cfu's) per 100 ml, nor shall they exceed 400 cfu's per 100 ml as a daily maximum. This monitoring shall be conducted concurrently with the TRC sampling described below.
7. The minimum level (ML) for total residual chlorine is defined as 20 ug/l. This value is the minimum level for chlorine using EPA approved methods found in the most currently approved version of Standard Methods for the Examination of Water and Wastewater, Method 4500 CL-E and G, or United States Environmental Protection Agency Manual of Methods of Analysis of Water and Wastes, Method 330.5. One of these methods must be used to determine total residual chlorine. For effluent limitations less than 20 ug/l, compliance/non-compliance will be determined based on the ML. Sample results of 20 ug/l or less shall be reported as zero on the discharge monitoring report.
8. The permittee shall include a report attached to the monthly Discharge Monitoring Reports (DMR's) notifying EPA and MADEP if a malfunction and/or interruption of the chlorine dosing process or dechlorination process occurs. The report shall include an explanation, and the duration of the malfunction and/or interruption, all actions taken to correct and prevent it, and a discussion on the impact on discharge levels of chlorine and bacteria.
9. The second TKN and nitrite/nitrate sample shall be collected 15 days after the first samples collected.
10. The permittee shall conduct chronic (and modified acute) toxicity tests four times per year. The chronic test may be used to calculate the acute LC₅₀ at the 48 hour exposure interval. The permittee shall test the daphnid, Ceriodaphnia dubia, only. Toxicity test samples shall be collected during the second week in the months of February, May, August, and November. The test results shall be submitted by the last day of the month following the

completion of the test. The results are due March 31, June 30, September 30, and December 31, respectively. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Dates Second Week in	Submit Results By:	Test Species	Acute Limit LC ₅₀	Chronic Limit C-NOEC
February May August November	March 31 June 30 September 30 December 31	<u>Ceriodaphnia dubia</u> (daphnid) See Attachment A	≥ 100%	≥ 45 %

After submitting **one year** and a **minimum** of four consecutive sets of WET test results, all of which demonstrate compliance with the WET permit limits, the permittee may request a reduction in the WET testing requirements. The permittee is required to continue testing at the frequency specified in the permit until notice is received by certified mail from the EPA that the WET testing requirement has been changed.

11. C-NOEC (chronic-no observed effect concentration) is defined as the highest concentration of toxicant or effluent to which organisms are exposed in a life cycle or partial life cycle test which causes no adverse effect on growth, survival, or reproduction at a specific time of observation as determined from hypothesis testing where the test results exhibit a linear dose-response relationship. However, where the test results do not exhibit a linear dose-response relationship, the permittee must report the lowest concentration where there is no observable effect. The " % or greater" limit is defined as a sample which is composed of 45% (or greater) effluent, the remainder being dilution water. This is a maximum daily limit derived as a percentage of the inverse of the dilution factor of 2.2.
12. The LC₅₀ is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.
13. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall follow procedures outlined in **Attachment A Section IV., DILUTION WATER** in order to obtain permission to use an alternate dilution water. In lieu of individual approvals for alternate dilution water required in **Attachment A**, EPA-New England has developed a Self-Implementing Alternative Dilution Water Guidance document (called "Guidance Document") which may be used to obtain automatic approval of an alternate dilution water, including the appropriate species for use with that water. If this Guidance document is revoked, the permittee shall revert to obtaining approval as outlined in

Attachment A. The "Guidance Document" has been sent to all permittees with their annual set of DMRs and Revised Updated Instructions for Completing EPA's Pre-Printed NPDES Discharge Monitoring Report (DMR) Form 3320-1 and is not intended as a direct attachment to this permit. Any modification or revocation to this "Guidance Document" will be transmitted to the permittees as part of the annual DMR instruction package. However, at any time, the permittee may choose to contact EPA-New England directly using the approach outlined in **Attachment A**.

Each toxicity test shall include a grab sample of the receiving water as a site diluent control.

Part I.A.1. (Continued)

- a. The discharge shall not cause a violation of the water quality standards in the receiving waters.
 - b. The pH of the effluent shall not be less than 6.0 nor greater than 8.3 at any time, unless these values are exceeded as a result of an approved treatment process.
 - c. The discharge shall not cause objectionable discoloration of the receiving waters.
 - d. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
 - e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand. The percent removal shall be based on monthly average values, and shall be reported on the monthly discharge monitoring report
 - f. When the effluent discharged for a period of 90 consecutive days exceeds 80 percent of the designed flow, the permittee shall submit to the permitting authorities a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.
 - g. The permittee shall minimize the use of chlorine while maintaining adequate bacterial control.
 - h. The results of sampling for any parameter above its required frequency must also be reported.
2. All POTWs must provide adequate notice to the Director of the following:
- a. Any new introduction of pollutants into the POTW from an indirect discharger in a primary industry category discharging process water; and
 - b. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 - c. For purposes of this paragraph, adequate notice shall include information on:
 - (1) the quantity and quality of effluent introduced into the POTW; and
 - (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
3. Prohibitions Concerning Interference and Pass Through:
- Pollutants introduced into POTW's by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.

4. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.

5. Numerical Effluent Limitations for Toxicants

EPA or DEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

B. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from outfall listed in Part I. A.1. of this permit. Discharges of wastewater from any other point sources, are not authorized by this permit and shall be reported in accordance with Section D.1.e (1) of the General Requirements of this permit (twenty-four hour reporting).

C. SCHEDULE OF COMPLIANCE

The new phosphorus limits in the permit allows a compliance schedule of one year from the effective date of the permit for the permittee to come into compliance. Therefore for the first year, the permittee will only report the phosphorus concentration and mass while working towards meeting the limits.

D. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions. Where the permittee may not

have the jurisdiction to satisfy these conditions, it shall enter into agreements, contracts, or MOUs with its member communities to assure that these conditions are met.

1. Maintenance Staff

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

2. Preventative Maintenance Program

The permittee shall maintain an ongoing preventative maintenance program to prevent overflows and bypasses caused by malfunctions or failures of the sewer system infrastructure. The program shall include an inspection program designed to identify all potential and actual unauthorized

discharges.

3. Infiltration/Inflow Control Plan:

The permittee shall develop and implement a plan to control infiltration and inflow (I/I) to the separate sewer system. The plan shall be submitted to MA DEP and available to EPA upon request for review within six months of the effective date of this permit (see page 1 of this permit for the effective date). The plan shall describe the permittee's program for preventing infiltration/inflow related effluent limit violations, and all unauthorized discharges of wastewater, including overflows and by-passes due to excessive infiltration/inflow.

The plan shall include:

- An ongoing program to identify and remove sources of infiltration and inflow. The program shall include the necessary funding level and the source(s) of funding.
- An inflow identification and control program that focuses on the disconnection and redirection of illegal sump pumps and roof down spouts. Priority should be given to removal of public and private inflow sources that are upstream from, and potentially contribute to, known areas of sewer system backups and/or overflows.
- Identification and prioritization of areas that will provide increased aquifer recharge as the result of reduction/elimination of infiltration and inflow to the system.
- An educational public outreach program for all aspects of I/I control, particularly private inflow.

Reporting Requirements:

A summary report of all actions taken to minimize I/I during the previous calendar year shall be submitted annually by the anniversary date of the effective date of this permit to the MA DEP and available to EPA upon request.. The summary report shall, at a minimum, include:

- A map and a description of inspection and maintenance activities conducted and corrective actions taken during the previous year.
- Expenditures for any infiltration/inflow related maintenance activities and corrective actions taken during the previous year.
- A map with areas identified for I/I-related investigation/action in the coming year.
- A calculation of the annual average I/I, the maximum month I/I for the reporting year.
- A report of any infiltration/inflow related corrective actions taken as a result of unauthorized discharges reported pursuant to 314 CMR 3.19(20) and reported

pursuant to the Unauthorized Discharges section of this permit.

3. Alternate Power Source

In order to maintain compliance with the terms and conditions of this permit, the permittee shall continue to provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §122.2).

E. SLUDGE CONDITIONS

1. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
2. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
3. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices.
 - a. Land application - the use of sewage sludge to condition or fertilize the soil
 - b. Surface disposal - the placement of sewage sludge in a sludge only landfill
 - c. Sewage sludge incineration in a sludge only incinerator
4. The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid waste landfill. These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (lagoons- reed beds), or are otherwise excluded under 40 CFR 503.6.
5. The permittee shall use and comply with the attached sludge compliance guidance document to determine appropriate conditions. Appropriate conditions contain the

following elements. See Attachment B, Sludge Guidance.

- General requirements
- Pollutant limitations
- Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
- Management practices
- Record keeping
- Monitoring
- Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.

6. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year

less than 290	1/ year
290 to less than 1500	1 /quarter
1500 to less than 15000	6 /year
15000 +	1 /month

7. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR 503.8.
8. The permittee shall submit an annual report containing the information specified in the guidance by February 19. Reports shall be submitted to the address contained in the reporting section of the permit. Sludge monitoring is not required by the permittee when the permittee is not responsible for the ultimate sludge disposal. The permittee must be assured that any third party contractor is in compliance with appropriate regulatory requirements. In such case, the permittee is required only to submit an annual report by February 19 containing the following information:

- Name and address of contractor responsible for sludge disposal
- Quantity of sludge in dry metric tons removed from the facility by the sludge contractor

F. MONITORING AND REPORTING

1. Reporting

Monitoring results obtained during each calendar month shall be summarized and reported on separate Discharge Monitoring Report Form(s) postmarked no later than the 15th day of the following month.

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency
Water Technical Unit (SEW)
P.O. Box 8127
Boston, Massachusetts 02114

The State Agency is:

Massachusetts Department of Environmental Protection
Bureau of Resource Protection
Southeast Regional Office
20 Riverside Drive
Lakeville, MA 02347

Signed and dated Discharge Monitoring Report Forms and toxicity test reports required by this permit shall also be submitted to the State at:

Massachusetts Department of Environmental Protection
Division of Watershed Management
Surface Water Discharge Permit Program
627 Main Street, 2nd Floor
Worcester, Massachusetts 01608

G. STATE PERMIT CONDITIONS

This Discharge Permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (DEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MA DEP pursuant to M.G.L. Chap.21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of this Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this Permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this Permit is declared invalid, illegal or otherwise issued in violation of Federal law, this Permit shall remain in full force and effect under State law as a Permit issued by the Commonwealth of Massachusetts.